



SITE DESIGN
LANDSCAPE ARCHITECTURE
URBAN PLANNING

Project Name: Girls Softball Field Renovation

Date: 9.24.18

Addendum #: 2

1. Prebid meeting was mandatory
2. Sign in sheet is attached
3. The town will accept pulverized sod if contractor delivers to town facility
4. Warning track material is specified in section 321500
5. Contractor is responsible for picking up gravel at the town facility. Town personnel will load it
6. The water line can be 18" deep, not 5' as detailed
7. Dugouts are on a 5" thick concrete pad. Pad to be flush with adjacent surface
8. All additional questions should go to To Design
9. Infield clays to be purchased from DeSiato Sand and Gravel

Prospective bidders and all others concerned are hereby notified of the following additions to the referenced bid. All changes will become part of the final contract documents.

All other terms and conditions remain the same

TOWN OF COLUMBIA GIRLS SOFTBALL FIELD SOLICITATION NUMBER 2018-04

DATE	NAME	COMPANY	PHONE NUMBER	EMAIL ADDRESS
9-24-18	KEVIN FOLEY	LIBERTY LANDSCAPES	(860) 289-8073	katherine@liberty498.com
9-24-18	NATHAN COLLINS	RAD SPORTS	774-269-1961	NAC@RADSPORTS.COM
9-24-18	Jim Galey	Earth Dynamics	860-424-2226	Earthdynamicsllc@gmail.com
9/24/18	Steve Zato	Mountain View Inc	413-536-7555	stevez@mountainviewinc.com
9/24/18	Mark Pelkey	Stonehedge LLC	860-485-3348	mark@pelkey@icloud.com
9/24/18	Jerry Wilcox	Wilcox Excavating Inc	860-644-8574	Wilcoxexc@aol.com
9/24/18	Gary Payne	Cornerstone Fence + ornamental Gate LLC	203-237-4283	gary.cornerstonefence@yahoo.com
9/24/18	Josh Suchocki	Suchocki's Son	860 917 4153	Josh@Suchockiandson.com
9/24/18	Brian Comborz	H.E. Butler Const	860 342-3880	BB@HBTULCONSTRUCTION.COM
9-24-18	Dave Zaleski	Northland Construction	860 982 7796	dave.northland@snet.net